

A Fire at KEK LINAC and Its Recovery

Kazuro Furukawa

<kazuro.furukawa@kek.jp>


for KEK e⁻/e⁺ Injector LINAC

Fire and Recovery at Injector Linac

K.Furukawa, KEK, Oct.2021. 1/25




Injector Linac Building and Assembly Hall




Accelerating Structure Test Facility in the Assembly Hall

Adjacent to the south of the injector building

- ***** X-band, C-band, S-band developments
- Nextef : research collaboration with CERN and US labs. (for 13 years)
 - **¤** 150 MW high-power pulsed power modulator
- On the 2nd day of a planned 3-month work
- Planned to be used for S-band from FY2020





Fire and Recovery at Injector Linac

(Apr.2.2019.)

Fire at Injector Linac Building

- A fire broke out at the assembly hall adjacent to the injector building
 - The hall was used for R&D of S-band, C-band, X-band structures
 - On the day, a collaboration research program with CERN/SLAC for X-band

A fire started in a microwave high-power modulator

- \asymp X-band microwave: 11.424 GHz, 10 100 MW, 1 μ s, 50 Hz
- An aged capacitor in the pulse-forming network (PFN) burst, discharged, ignited

High-power interlocked, fire-alarm triggered, much smoke

Fortunately, no injury

Most of equipment was damaged

- imes S-band development at the test-stand was important, and recovered at early 2020
- **X**-band devices were much more damaged, and approved to restart in this month, Sep.2021

Fire stopped when firemen entered (1.5 hour later)

- No media/press investigation (on site)
 - "No environmental hazards found" on TV and papers
 - X While "no environmental hazards" was surely true, the reality was so disruptive



Finding Overview

- No injury (could not enter the hall because of smoke)
- Self-extinguished when firemen entered with oxygen
- No direct fire damage to the main injector linac...
- Large amount of carbon soot sneaked into the injector
 - Discharge might prevent high-voltage operation of high-power pulsed modulators
 - Short-circuit might prevent high-precision operation of the instrumentation

Chemical material (Dioctyl Phthalate: cancer causing) accompanied with carbon soot

- Required full Tyvek protective clothing
 - I Later, it turned out that the density was rather low, and the clothing was relaxed

Quick recovery required for SuperKEKB commissioning

- Large discrepancy in understanding between the institute and the division
- Investigated technical aspects, resources, and mental health, etc
 - **¤** Finally, succeeded in tentative recovery



Early Difficulties

- We entered into buildings just after the extinguishing, however, firemen evacuated us as the level of carbon mono-oxide was high
- The damage in the assembly hall was obvious, however, the impact of carbon soot was significant to the main injector LINAC, that was not recognized by the institute
 - We were told to restart within 3 days
 - However, we estimated that it may take 1-3 months

Limited material availability

- Only about 8 sets of protective clothing and masks were available in nearby cities. During the weekend, group leaders started to investigate the damage and to plan the recovery works
- Later, purchased hundreds of material sets of Tyvek clothing, gas masks with active charcoal, gloves, shoe covers, etc.



Chemical Hazard

Carbon soot was collected immediately for chemical analysis

It takes a month for quantitative analysis normally

Partial analysis on site

- Only for soluble in organic solvent
 - Dioctyl Phthalate (softener for vinyl chloride)
 - Cancer causing, reproductive toxicity, etc
 - rightarrow (A month later, found to be safe as the density was too low)

Full protective clothing (Tyvek) (needed also for soot)

- Detailed explanation was made to contractors as well
- **¤** Youth and women were excluded from the workers
- Gas masks, Tyvek, goggles, gloves, entrance management
 - I Gas masks were ordered directly to the factory in hundreds
- Conversation, face-recognition, ...
 - ズ Names on front/back of Tyvek
- Air temperature rise
 - \bowtie Water and food at the entrance
 - Daily health suggestions from doctor





Fireman in the smoke and carbon soot





Modulator burnt



Fire and Recovery at Injector Linac





Carbon soot sneaked through holes between rooms








Carbon soot in the equipment









Cleanup one by one





Low-power & high-power tests



Information Sharing via Meeting, Mail and Web

- Meeting in every morning
 - 💢 Some from other divisions
- Group leader meeting in every evening
- Daily update
- Mental health
- Physical health
- Environmental analysis
- Recovering strategy
- Utility recovery
- Equipment recovery
- Testing progress
- Beam schedule

、射器火災復旧について (Lin <mark>ac Fire Recovery, April - November 2019</mark>)
<u>ストレスイベント後の反応について (安全衛生推進室、大井雄一産業医)(Response after stress event, May.10) [pdf]</u>
<u>電子陽電子入射器の作業者のみなさまへ (環境安全管理室, 安全衛生推進室)(Linac safety reminder, Oct.30, NEW</u>) [p
こころのケアについて (安全衛生推進室, 健康相談室) (Mental care, Apr.19)[pdf]
揮発性有機化合物調査結果と作業管理 (環境安全管理室,安全衛生推進室) (Gas analysis and healthcare, May.27) [pdf] :[word
保護具に関する作業管理の質問と回答 (安全衛生推進室) (Gas mask and healthcare Q&A, Apr.22) [pdf]
保護具に関する作業管理と健康管理 (安全衛生 <mark>推進室) (Gas mask and healthcare, Apr.19) [pdf]</mark>
入射器棟粉塵濃度測定結果と今後の作業における注意 (Dust assessment and recovery, Apr.17) [pdf]
化学物質情報概要 (Chemical overview, Apr.6) [pdf]
化学物質情報 (SDS) [pdf] :[Original link]
入射器入域安全確保 (Linac safety, Apr.5, OBSOLETE) [pdf]安衛室分析 (Chemical analysis, Apr.5, OBSOLETE) [pdf]
安全衛生推進室巡視点検報告 (衛生管理者,安全衛生管理者) (Safety health inspection, May.9) [pdf] :[word]
安全衛生推進室巡視点検報告 (産業医,産業看護師) (Safety health inspection, May.9)[pdf] : [word]
安全衛生推進室巡視点検報告 (Safety inspection, Apr.11) [mail] : [word]
入射器 Beam 立ち上げ進捗 (Linac restart progress, Apr.25) [pdf] : [excel]
入射器復旧作業進捗 (Linac recovery progress, Apr.19) [pdf] : [excel]
入射器 Beam 立ち上げ進捗概要 (Linac restart progress overview, Apr.24) [pdf]
火災報知設備と加速器運転 (Fire alarm and operation, Apr.19) [pdf]
施設部復旧情報 (Utility recovery daily progress <mark>, Apr.26) [pdf]</mark>
施設部復旧情報 (Utility recovery daily progress, Apr.24) [pdf]
サブ変電室回復情報 (Substation recovery progress, Apr.16) [pdf]
<u>対策会議報告と立上げ打合せ (Recovery daily progress report, Apr.22) [mail] : [powerpoint]</u>
<u>対策会議報告 (Recovery daily progress report, Apr.19) [mail] :[powerpoint]</u>
<u>火災について(共同利用者の方へ)[KEK News] : To KEK Users: On the</u> fire, <u>Apr.25 [English]</u>
<u>火災について(共同利用者の方へ)_[KEK News]</u> : To KEK Users: On the fire, Apr.11 [English]
<u>火災について [KEK Press release]</u> : Fire at linac, Apr.4 [English]
入射器入域手順 (Linac entrance procedure, Apr.8) [pdf]
入射器概略図面 (Linac floor plan) [pdf]
<u>Gallery 概略図面 (Gallery floor plan) [pdf] :Tunnel 概略図面 (Tunnel floor plan) [pdf] :空調範囲図面 (Airconditioner floor p</u>
<u>詳細 Mail 共有情報 (Linac-Update mail archive)</u>
<u>入射器復旧写真 (Linac recovery photo archive)</u>
加速器学会報告 (Report at particle accelerato <mark>r society, Aug.2) [pdf]</mark>
<u>火災報告 (Analysis report, Jun.28) [pdf]</u>
暫定報告 (Tentative report, May.10) [pdf]
火災概要 (Incident overview slide, Apr.8) [pdf]
火災概要 (Incident overview slide, Apr.5) [pdf]
<u>火災概要報告 (Incident overview 3-page report, Apr.4) [pdf]</u> 時系列記録 (Timeline) [html]

Kazuro Furukawa <linac-request@mail-linac.kek.jp>, Apr.7-Oct.30.2019. [Linac] [Linac-update] [SuperKEKB] [Accelerator] [KEK Staff] [KEK]

NHK 首都圏 (Apr.4) : つくば市 (Apr.4)

Exploration of the Landing Position

- Negotiation between early recovery and limitations
- Might take several months to recover all devices
- Abandoned redundancies in certain devices
- Important devices that might need long recovery period
 - Several of 60 high-power microwave modulators
 - x Some of them act as redundancies
 - Two magnet power-supplies for 180-degree bending section (J-ARC)
 - imma One backup existed, fortunately stored in a distant room

Investigated the beam energy profile around J-ARC

 If it took more than 3 weeks, limited mon-power inside/outside because of consecutive national holidays in May (Golden week)



Recovery progress

Apr.3: Fire. Carbon soot was anticipated for high-power and high-precision operation.

Apr.4: During the investigation, hazardous chemical material was found as well as carbon soot.

Apr.5, 6: Partial clean-up was performed as a test, and also for devices to be sent out to maker companies, with limited pieces of protective clothing.

Apr.8: As protective clothing arrived, full clean-up started. Several devices were found to be difficult to fix in a short term, and an operation plan was developed.

Apr.18: Low power test started.

Apr.22, 23: High power test was performed successfully.

Apr.23: Beam test began.

Apr.25: Limited SuperKEKB HER injection restarted.

Apr.26: SuperKEKB HER and LER injections, and then the collision restarted.

May.7: PF light source injection started as originally scheduled.

Recovered with much help from everyone

All divisions in KEK and outside companies joined

Certain equipment recovery was postponed

- Energy lowered from 1.5 GeV to 1.35 GeV

Until summer shutdown

- □ 2 of 60 RF sources were off
- I of 2 bending magnet power supplies was off

Found not to impact much on the injection

- x with the required beam specifications at the time (just after the commissioning)
- Mostly recovered before autumn operation

Most of backup devices were consumed

- Many damaged devices were abandoned
- * Might mean acceleration of renewal for aging devices, actually
- Budget depended on insurance refund



Investigations and Countermeasures

A review meeting was organized in the accelerator department, and later was endorsed by the institute as well

Fact

- A capacitor with plastic container in the pulse forming network of high-power modulator punctured, discharged, and fired
- The modulator was restarted after the initial interlock without detailed investigations

Recommendations

- Usage of metal (or ceramic) container capacitors
- Conservative (long-life) capacitor design with lower gradient
- Routine inspection of characteristics of capacitors
- Rigid interlock handling
- Improve the sensors and video cameras
- Documentations especially with power board connections
- Tight communication between main injector operation and test-stand experiments

WAO 2021

Auto-extinguisher and Cameras

- We experienced punctures before
- We learnt that several other institute experience such fire incidents
 - At least we got information from SLAC and CERN
- An automatic extinguisher was installed in the new Nextef modulator
 - A smoke sensor triggers non-combustible gas into PFN box
- Hundred of video cameras were installed to observe interlocked devices in main LINAC





18 / 25

Operation Considerations

- Capacitors at injector are different from Nextef's
 - Has ceramic container instead of plastic container
 - Has lower designed potential gradient (longer lifetime)
 - Has puncture protection

Fire and Recovery at Injector Linac

- Performed degradation check every other summer (tangent delta)
- Tentative operation procedure in injector linac
 - Local operator investigation is enforced on modulator HV interlock
 - times Observation for any anomalous behavior or capacitor puncture
 - More frequent observation of southern part of injector
- More surveillance devices would be installed
- Important to start S-band structure assembly in 2020
 - As originally planned to fight against aging structures
 - Structure assembly room should be recovered early

Careful knowledge transfer from the original designer to the next generation







Impact on SuperKEKB Operation

Beam suspension for 3 weeks

- i at the first stage of phase 3 operation
- i at the middle of luminosity development





Fire and Recovery at Injector Linac


K.Furukawa, KEK, Oct.2021. 20/25



Simultaneous 4 + 1 Ring Top-up Injection


Realized for the first time

- ≍ SuperKEKB HER 7 GeV e-
- □ SuperKEKB DR and LER 4 GeV e+
- ¤ PF-AR 5.0 / 6.5 GeV e-
- 4 beams are modulated at 20 ms PPM
- More than 200 pulsed devices were constructed for SuperKEKB, as well as beam and RF monitors
- Injection noise (background) were well studied from the 2nd week of May



K.Furukawa, KEK, Oct.2021. 21/25

Simultaneous Top-up Injections Integrated luminosity improvement (example)



Fire and Recovery at Injector Linac

K.Furukawa, KEK, Oct.2021. 22/25




Trans-science

I was much astonished to see such a big disaster in our facility

That reminded a word "Trans-science" by Alvin Weinberg

- He invented the light-water reactor in Navy for submarine, but insisted that it is too dangerous for civilian applications. Later, he as the director general of ORNL invented Thorium molten-salt reactor. But the world didn't appreciate him until recently.
- If the probability of an incident is very low, we make mistakes in the evaluation, and tend to or try to forget that.

We need to keep balance between many conditions with pursuing scientific evaluations.






Summary

- We should not have the same disaster, with better preparation
- We could have learnt from other institutes
- We could be very nervous in unusual situation, be prepared
- We've mostly recovered from the disaster
- Active safety measures are necessary instead of reacting only
- We are improving with the experiences

With some Phronesis we can enjoy accelerators

Phronesis [Greek]: Practical wisdom, Ability to understand the Universal Truth



Conference papers at http://www-linac.kek.jp/linac/

Fire and Recovery at Injector Linac

