

Skyshine Dose Estimation from Large Storage Ring of Electrons

Toshiso KOSAKO, Takeshi IIMOTO, Nobuyuki SUGIURA and Toshio KAWANISHI
The University of Tokyo
Research Center for Nuclear Science and Technology
Yayoi 2-11-16, Bunkyo-ku, Tokyo 113-0032, Japan

Abstract

For high energy and large-scale accelerator, dose estimation of skyshine at the facility boundary is very important to achieve the dose limit to the public. Here skyshine dose estimation was done by using calculation to obtain a design concept of the synchrotron facility which had a linear accelerator and a large scale storage ring of 1-2 GeV electrons. Through the detailed consideration a basic ideas are obtained under several operation modes.

1 Introduction

We are promoting the project of Synchrotron Radiation Facility in Kashiwa New Campus of the University of Tokyo. For the accelerator building construction, shielding design and their radiation dose estimations are requested. Shielding calculations are categorised into two parts: bulk shielding and skyshine. Here we would like to discuss about the skyshine dose from this accelerator facility.

There are several accelerator designs. One is a 400 MeV linear accelerator (LINAC) and a 2 GeV storage ring (SR), another is a 1 GeV linear accelerator and a 1 GeV storage ring. These situations may change depending on the final decision of the plan. Here several discussions are done for the base of design by performing a typical calculation of skyshine phenomena to these designs.

So we did a setting of typical case as: Phase I, having 400 MeV LINAC [on the ground] and 2 GeV SR [on the ground] (see Fig.1), Phase II, having 1 GeV LINAC [in the underground] and 1 GeV SR [on the ground] (see Fig.2).

2 Method of Shielding Calculation

For the estimation of skyshine dose, the equation of Stevenson-Thomas[2,3,4] was applied.

$$H = 3.0 \times 10^{-15} \exp(-r/\lambda) / r^2 \times S \times 3600$$

Here,

- H : skyshine dose (Sv/h)
- λ : attenuation length in air of high energy neutrons (m)
- r : distance from a source to a considering point
- S : total neutron source intensity on the surface of building ceiling (n/s)

Point neutron source was assumed in the skyshine dose calculation.

For Phase I: source points were 4 at LINAC (e⁻/e⁺

converter and 3 slits), and 33 at Storage Ring (32 bending magnets and one beam injection point).

For Phase II: Source points were set only for the storage ring because the linear accelerator was set under the ground and caused less dose contribution to the skyshine. The 24 point sources distributed on the race track storage ring.

The procedure of source term neutron intensity estimation on the ceiling is as follows.

- ① Bulk shielding estimation on the ceiling by the Jenkins formula[1].
- ② Neutron flux estimation based on the obtained dose by assuming 1/E spectrum.
- ③ Total neutron intensity, S, estimation by multiplying total ceiling surface.
- ④ Skyshine estimation by Stevenson-Thomas formula to each point source.
- ⑤ Total skyshine estimation by summing up each dose component from each source points.

This method gives conservative dose estimation because the assumption of 1/E is a safety side discussion and the Stevenson-Thomas formula is overestimation within about 100 m distance.

3 Accelerator Operation Mode and Beam Loss

Operation modes are 5 pattern to LINAC and 10 pattern to Synchrotron Storage Ring. LINAC has an energy of 0.3-1 GeV to electron or positron and its modes are ① electron short pulse ② electron semi-long pulse ③ electron long pulse ④ positron short pulse ⑤ positron semi-long pulse. Storage ring has a maximum energy of 2 GeV and its modes are ① multi bunch operation (accumulation) ② multi bunch operation (injection) ③ single bunch operation (accumulation) ④ single bunch operation (injection) ⑤ start up adjustment ⑥ operation under baking ⑦ machine study ⑧ machine study for injector ⑨ start up adjustment for injector ⑩ stand by. The beam parameters like beam energy, peak current, pulse width, duty cycle, duty factor, average current, beam intensity, beam loss rate and beam loss, were given to each parameter and to each region.

Beam loss rate is a very important parameter and was given by an empirically estimated value based on experiments. The used values are listed in Table 1.1 and 1.2. It is noted that these values are safe side values to keep the conservative shielding result.

4 Dose Estimated Result

4.1 Result of Phase I

The estimated annual dose to each facility were shown in Table 2.1 and 2.2 to LINAC and SR respectively. By adding skyshine dose and direct dose, we could obtain the total dose to each points (see Table 3). The nearness of the site boundary gives a little higher value. The marking point is a value at the 5th floor of control building (in Table 3). At that point a little high value was obtained for the reasons of reaching a little more direct arrival of radiation (not so much skyshine).

The targeting dose level is 50 μ Sv/y for skysine at the site boundary. The dose limitation to the public given by ICRP (International Commission on Radiological Protection) is 1 mSv/y. In this meaning the obtained value is sufficient.




Fig.1 Disposition of LINAC and SR (Phase I)

4.2 Result of Phase II

Next, the phase II situation was estimated. In this case 1 GeV LINAC locate in the underground. That means no estimation was needed for the environment dose at he boundary. 1 GeV racetrack type storage ring was considered for skyshine source.

The same procedure was used for the skyshine dose estimation as Phase I. Skyshine point sources in the storage ring are 24. These skyshine component and direct component of neutrons were summing up and the tabulated (see Table 4). These values are smaller than the phase I. This is because the following reasons: ①energy is smaller ②small size of storage ring gives a large distance to a boundary ③change of the distribution of sources.




Fig.2 Disposition of LINAC and SR (Phase II)

6 Conclusion

By using the calculation we could estimate skyshine neutron dose estimation around high-energy electron storage ring used for synchrotron orbit radiation. The detailed discussion of source term was done by introducing several operation modes and segmentation of radiation generation points. The obtained typical results of Phase I and Phase II will be effectively used for the efficient designing of this facility.

References

- [1] T.M. Jenkins, Nucl. Instrum. Meth., 159, 265 (1979).
- [2] R.H.Thomas et al., NIRL/M/30, Rutherford Laboratory, Cambridge University (1962).
- [3] P H.Thomas, in Engineering Compendium on Radiation Shielding, 1, 56, Springer-Verlag, Berlin (1968).
- [4] G.R.Stevenson et al., Health Physics 46, 115 81985).

Table 1.1 Beam Loss Ratio of Lineac

| | |
|----------------------|------|
| input | 30% |
| first slit | 10% |
| second & third slits | 2% |
| beam dump | 100% |
| e-/e+ converter | 100% |
| line accelerator | 1% |

Table 1.2 Beam Loss Ratio of Storage Ring

| | | |
|-------------------|----------------|-----|
| adjustment period | incidence area | 95% |
| | others | 5% |
| beam input period | incidence area | 95% |
| | others | 5% |
| storage period | incidence area | 80% |
| | others | 20% |

Tab2.1 Annual Dose around LINAC (Phase I)

| site ID | area | machine room (up side) | | | klystron room (side) | | | |
|---------|-----------|--------------------------|--------------------|-------------------|--------------------------|-----------------|----------------|----------------|
| | | bulk shield thickness cm | point shielding cm | annual dose mSv/y | bulk shield thickness cm | wall side mSv/y | 1m apart mSv/y | 3m apart mSv/y |
| 1 | lineac | OC 250 | | 3.6 | OC 200 | 116.5 | 70.5 | 33.8 |
| 2 | slit | OC 250 | | 0.8 | OC 200 | 27.2 | 16.5 | 7.9 |
| 3 | lineac | OC 250 | | 2.7 | OC 200 | 48.8 | 29.5 | 14.2 |
| 4 | slit | OC 250 | | 5.3 | OC 200 | 96.6 | 58.4 | 28.0 |
| 5 | lineac | OC 250 | | 2.6 | OC 200 | 47.3 | 28.6 | 13.7 |
| 6 | converter | OC 250 | Fe 25 | 6.6 | OC 200 | 42.5 | 25.7 | 12.3 |
| 7 | lineac | OC 250 | Fe 5 | 19.7 | OC 200 | 223.8 | 135.4 | 64.9 |
| 8 | slit | OC 250 | Fe 20 | 18.3 | OC 200 | 443.6 | 268.3 | 128.6 |
| 9 | lineac | OC 250 | Fe 5 | 19.2 | OC 200 | 217.5 | 131.6 | 63.1 |

Tab2.2 Annual Dose around SR (Phase I)

Beam incidence area

| source | annual operation period | estimated site ID and Sv | | | | unit |
|----------------------------|-------------------------|--------------------------|-----------|-----------|-----------------|------------|
| | | A-1 | A-2 | B-1 | B-2 | |
| | forward | S2,S3 | S2,S3 | S3,S0 | S0,S4,S5 | |
| | side | S0 | S0 | S4 | | |
| forward shielding | OC | 65 | 65 | 65 | 65 | cm |
| | Pb | 15 | 20 | 40 | 15 | cm |
| side shielding | OC | 60 | 60 | 60 | 60 | cm |
| | Pb | 0 | 15 | 0 | 0 | cm |
| forward distance to source | | 10.3, 3.0 | 16.5, 8.2 | 13.5, 6.5 | 17.5, 10.3, 3.0 | m |
| side distance to source | | 5.8 | 4.8 | 3.0 | | m |
| annual dose | | 17.3 | 9.6 | 11.1 | 9.3 | mSv/y |
| multi-banti-mode(input) | 4000h | 0.703 | 0.386 | 0.480 | 0.771 | μ Sv/h |
| multi-banti-mode(store) | 320h | 23.838 | 13.180 | 14.176 | 10.253 | μ Sv/h |
| single-banti-mode(input) | 500h | 0.031 | 0.017 | 0.021 | 0.034 | μ Sv/h |
| single-banti-mode (store) | 80h | 0.532 | 0.294 | 0.338 | 0.229 | μ Sv/h |
| preparation 1 | 150h | 5.036 | 2.784 | 3.206 | 2.160 | μ Sv/h |
| preparation 2 | 200h | 15.107 | 8.353 | 9.618 | 6.479 | μ Sv/h |
| machine study | 400h | 7.553 | 4.176 | 4.809 | 3.239 | μ Sv/h |

Other than beam incidence area *forward bulk shielding 80cm (OC65+Pb15) side bulk shielding 60cm (OC)*

| | annual operation period | estimated site ID and Sv | | | | | unit |
|----------------------------|-------------------------|--------------------------|-------|-------|-------|-------|------------|
| | | C-0 | C-1 | C-2 | C-3 | C-4 | |
| forward distance to source | | | 9.8 | 15.0 | 10.3 | 14.5 | m |
| side distance to source | | 1.5 | 3.0 | 1.5 | 3.0 | 1.5 | m |
| annual dose | | 1.74 | 0.20 | 1.75 | 0.20 | 1.75 | mSv/y |
| multi-banti-mode(input) | 4000h | 0.205 | 0.024 | 0.206 | 0.024 | 0.207 | μ Sv/h |
| multi-banti-mode(store) | 320h | 1.500 | 0.175 | 1.508 | 0.175 | 1.507 | μ Sv/h |
| single-banti-mode(input) | 500h | 0.009 | 0.001 | 0.009 | 0.001 | 0.009 | μ Sv/h |
| single-banti-mode (store) | 80h | 0.033 | 0.004 | 0.034 | 0.004 | 0.034 | μ Sv/h |
| preparation 1 | 150h | 0.317 | 0.037 | 0.318 | 0.037 | 0.319 | μ Sv/h |
| preparation 2 | 200h | 0.950 | 0.111 | 0.955 | 0.111 | 0.956 | μ Sv/h |
| machine study | 400h | 0.475 | 0.055 | 0.478 | 0.055 | 0.478 | μ Sv/h |

Tab3 Total Dose at the Boundary (Phase I)

| site ID | Border direction | Distance(m) | Annual dose(μ Sv/y) |
|---------|--------------------------------|-------------|--------------------------|
| 1 | NE | 63 | 33.4 |
| 2 | NW | 57 | 38.3 |
| 3 | 5th floor of control building* | 50 | 72.5 |

*directly arrival dose, not skyshine

Tab4 Total Dose at the Boundary (Phase II)

| Site ID | Border direction | Annual dose(μ Sv/y) |
|---------|------------------|-------------------------------------|
| Point A | NE | 3.8(Direct) + 10.2(skyshine) = 14.0 |
| Point B | NW | 0.03(Direct) + 5.1(skyshine) = 5.1 |